



Annexure-C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY
CONDITION CERTIFICATE

Roc.No 2941/2026/H1

Date: 29.09.2026


It is certified that an inspection team headed by Mr.P. Prathap Kumar from CITY HEALTH OFFICER VELLORE CITY MUNICIPAL CORPORATION, VELLORE inspected the SPRINGDAYS GARDEN SCHOOL, No. 26, Officers Line, Anna Salai, Vellore-632 001 on 29/09/2026 (date of inspection) and on the basis of Water Test Report (Attached) bearing No. TR/2026/67883 dated 14.08.2026 of DISTRICT WATER TESTING LABORATORY, VELLORE certified that the SPRINGDAYS GARDEN SCHOOL has safe drinking water facilities for the students and members of staff of the institution. School is also maintain the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/State/U.T. Govt.

This Certificate is valid till 28.09.2027.



SANITARY OFFICER

ZONE-III

VELLORE CITY MUNICIPAL CORPORATION


CITY HEALTH OFFICER

VELLORE CITY MUNICIPAL CORPORATION


To,

Correspondent

Springdays Garden School,

No. 26, Officers Line, Anna salai,

Vellore-632 001.

DATE:



TAMILNADU WATER SUPPLY AND DRAINAGE BOARD
DISTRICT WATER TESTING LABORATORY
Opp. Muthu Mandapam, Old Katpadi Road, Vellore.632 004
Phone: 0416-2215168. E-Mail: twadlabphotos2021@gmail.com



TEST REPORT

Doc. No: DWTL/FORM/7.8/01

Report No.	TR/2026/67883	Report Issue Date	14.08.2026	Page No: 01 of 02
Invoice Details	11827/ dt:10.08.2026	ULR. No.	TC163372600000000883F	

Client Name & Address	Spring days Garden School.			
Contact	No.26,Officer's Line, Anna Salai,			
No./Email.ID	Vellore.632 001.			
Sample Submitted by	: K.Sivakumar			
Sample Location	: Near Gate			
Sample Description	: Clear Colorless Liquid			
Sample Name	: Water – Drinking Water	Sample Source	:	Drinking water
Sample/Lab No.	: 2026/67883	Sample Container	:	Plastic – Good
Quantity of sample Received	: 2 lit	Sample Condition	:	Good
Sample Received on	: 10.08.2026	Temperature / Humidity %	:	25°C / 50%
Test Commenced on	: 10.08.2026	Test Completed on	:	12.08.2026

S. No	Parameters	Test Method	Unit	Result (2026/67883)	Specification as per IS 10500:2012(RA:2023)	
					Acceptable Limit	Permissible Limit in the absence of alternate source
1	Colour	IS3025:Part4: 2021	Hazen	<1	5	15
2	Odour	IS3025:Part5: 2018	--	Agreeable	Agreeable	Agreeable
3	Taste	IS3025:Part8: 2023	--	Agreeable	Agreeable	Agreeable
4	Turbidity	IS3025:Part10: 2023	NTU	<0.5	1	5
5	pH@25°C	IS3025: Part11: 2022	--	7.23	6.5-8.5	No Relaxation
6	Total Dissolved Solids	IS3025:Part16: 2023	mg/L	959	500	2000
7	Total Alkalinity as CaCO ₃	IS3025: Part23: 2023	mg/L	308	200	600
8	Total Hardness as CaCO ₃	IS3025: Part21:2009 (RA:2023)	mg/L	412	200	600
9	Calcium as Ca	IS3025:Part40: 2024	mg/L	80	75	200
10	Magnesium as Mg	IS3025:Part46: 2023	mg/L	51	30	100
11	Chloride as Cl	IS3025:Part32: 1988(RA:2019)	mg/L	214	250	1000
12	Nitrate as NO ₃	APHA 24 th Edn – 4500 – NO ₃ – B – 2023 (Screening Method)	mg/L	10	45	No Relaxation
13	Fluoride as F	APHA 24 th Edn – 4500 – F – D – 2023 (Spadns Method)	mg/L	0.6	1.0	1.5
14	Sulphate as SO ₄	APHA 24 th Edn – 4500 – SO ₄ – E – 2023 (Turbidimetric Method)	mg/L	110	200	400

Remark: The sample conform to IS: 10500:2012(RA:2023) Drinking Water Acceptable Limit / Permissible Limit specification with respect to above tested parameters of Physical & Chemical.

The test results relate only to the items tested.

The result applied to the sample as received basis.

The test items will not be retained for more than 15 days from the date of issue of the test report

BDL: Below Detection Limit; DL: Detection Limit; NT: Not Tested (Bacteriologically unsafe)

The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.

.....End of the Report.....

(Signature)
Authorized Signatory
M.S. NARENDIRAN, M.Sc
Junior Water Analyst
DWTL - Vellore

Issue No./Date	01/10.01.2021	Amend. No./Date	01/02.01.2026	Page No.	1 of 2
----------------	---------------	-----------------	---------------	----------	--------



TAMILNADU WATER SUPPLY AND DRAINAGE BOARD
DISTRICT WATER TESTING LABORATORY
Opp. Muthu Mandapam, Old Katpadi Road, Vellore.632 004
Phone: 0416-2215168. E-Mail: twadlabphotos2021@gmail.com

TEST REPORT

Doc. No: DWTL/FORM/7.8/01

Report No.	TR/2026/67883A	Report Issue Date	14.08.2026	Page No: 02 of 02
Invoice Details	11827/ dt:10.08.2026			

S. No	Parameters	Test Method	Unit	Result (2026/67883 A)	Specification as per IS 10500:2012(RA:2023)	
					Acceptable Limit	Permissible Limit in the absence of alternate source
1	P. Alkalinity as CaCO ₃	IS3025:Part23: 2023	mg/L	Zero	--	--
2	Manganese as Mn	IS3025(Part59) : 2023	mg/L	0.0	0.1	0.3
3	Ammonia as NH ₃ -N	IS3025(Part34) : 2019	mg/L	0.0	0.5	No relaxation
4	Nitrite as NO ₂	IS3025(Part34/Sec-1) :2023	mg/L	0.0	--	--
5	Iron	APHA 23rd Edition 2017-3500 Fe B	mg/L	0.0	0.3	1.0
6	Phosphate as PO ₄	IS3025(Part31/Sec-1) :2022	mg/L	0.0	0.0	0.0
7	Residual Chlorine	IS/APHA	mg/L	0.0	0.2	1.0

Bacteriological Test

1	Total Coliform	IS 15185: 2016 (RA: 2021)	CFU	Absence	Absence / 100 mL
2	Fecal Coliform	IS 15185: 2016 (RA: 2021)	CFU	Absence	Absence / 100 mL

Remark:

- The Tested sample conform to IS: 10500:2012(RA:2023) Drinking Water Acceptable Limit / Permissible Limit specification with respect to above tested parameters of Chemical.
- The Tested sample conform to IS: 10500:2012(RA:2023) Drinking Water Acceptable Limit / Permissible Limit specification with respect to above tested parameters of Bacteriological.

The test results relate only to the items tested.

The result applied to the sample as received basis.

The test items will not be retained for more than 15 days from the date of issue of the test report

BDL: Below Detection Limit; DL: Detection Limit; NT: Not Tested (Bacteriologically unsafe)

The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.

.....End of the Report.....

M. S. Narendiran
14/08/2026

Authorized Signatory
M.S. NARENDIRAN, M.Sc
Junior Water Analyst
DWTL - Vellore

Issue No./Date	01/10.01.2021	Amend. No./Date	01/02.01.2026	Page No.	2 of 2
----------------	---------------	-----------------	---------------	----------	--------